

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER FAILURE TO MONITOR

**ESTE INFORME CONTIENE INFORMACIÓN IMPORTANTE ACERCA DE SU AGUA POTABLE. HAGA QUE
ALGUIEN LO TRADUZCA PARA USTED, O HABLE CON ALGUIEN QUE LO ENTIENDA.**

Monitoring Requirements Not Met for Chlorine (Distribution System) & TTHM / HAA5

Our water system violated several drinking water standards over the past year. Even though these were not emergencies, as our customers, you have a right to know what happened and what we did to correct these situations.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During 4th Quarter 2020 and 2nd Quarter 2023 we failed to monitor Distribution Chlorine Residual and TTHM/HAA5 at the appropriate time due to sampling issues and therefore cannot be sure of the quality of our drinking water during that time.

What should I do?

There is nothing you need to do at this time.

The table below lists the contaminant(s) we did not properly test for during the last year, how often we are supposed to sample for Chlorine Residual and TTHM / HAA5 and how many samples we are supposed to take, how many samples we took, when samples should have been taken, and the date on which follow-up samples were (or will be) taken.

Contaminant	Required sampling frequency	Number of samples taken	When all samples should have been taken	When samples were or will be taken
Chlorine (distribution)	2x/month	1	10/5 - 10/9 2020 10/19 - 10/23 2020	2 nd sample was missed
TTHM	Quarterly	1	5/4 - 5/10 2023	06/08/2023
HAA5	Quarterly	1	5/4 - 5/10 2023	06/08/2023

What happened? What was done?

We originally collected the samples after the required sample collection timeframe. Additionally, the HAA5 sample was damaged at the laboratory and had to be re-collected.

For more information, please contact the Borough/Authority Manager _____ at 717-328-3116.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by the Mercersburg Water Authority _____.

PWS ID#: 7280021

Date distributed: 08/19/2024